

Statement of Compliance

No: 200 Rev B

Delta Mobrey Ltd.

Riverside Business Park, Dogflud Way, Farnham, Surrey,
GU9 7SS, United Kingdom

Declares under our sole responsibility:

Equipment: **Performance Series
Pressure, Differential Pressure and Temperature switches**

Type Numbers: ***2*****, *3*****, *7*******

(Minor variations in design to suit the application and/or mounting requirements are identified by alpha/numeric characters where indicated * above)

Ingress Protection Declaration

The products detailed above comply with the requirements of EN 60529 (IEC 60529) “Degrees of protection provided by enclosures (IP Code)” for degree of protection indicated below:

Enclosure	Model	Range	IP
A, W, N, O	201/202/203/281	All except BC, C6, E1, E8, BU, CP, E4, E7	66
A, W, N, O	201/202/203/281	BC, C6, E1, E8, BU, CP, E4, E7	54
H, K	201/202/203/281	All	66
All	All except 201/2/3/281	All	66

Authorised Signatory for the manufacturer:

Signed:



Date: 23rd July 2020

Eur Ing David J. Ross-Hamilton CEng MIMechE
Global Approvals Manager

Your Trusted Partner in Process Instrumentation