

1 **UK-TYPE EXAMINATION CERTIFICATE** 2 Equipment or Protective System Intended for use in Potentially Explosive Atmospheres UKSI 2016:1107 (as amended by UKSI 2019:696) - Schedule 3A, Part 1 3 **UK-Type** Examination BAS22UKEX0060X - Issue 1 Certificate Number:

- Sentry Series Pressure & Temperature switches 4 Product: 5 Manufacturer: **Delta Mobrey Ltd** Address: Hudson House, Albany Park, Camberley, Surrey, GU16 7PL 6 **United Kingdom**
- 7 This re-issued certificate extends UK-Type Examination Certificate No. **BAS22UKEX0060X** to apply to product designed and constructed in accordance with the specification set out in the Schedule of the said certificate but having any variations specified in the Schedule attached to this certificate and the documents therein referred to.
- 8 SGS Baseefa, Approved Body number 1180, in accordance with Regulation 43 of the Equipment and Protective Systems Intended for Use in Potentially Explosive Atmospheres Regulations 2016, UKSI 2016:1107 (as amended by UKSI 2019:696), certifies that this product has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of products intended for use in potentially explosive atmospheres given in Schedule 1 of the Regulations.

The examination and test results are recorded in confidential Report No. See Certificate History

9 Compliance with the Essential Health and Safety Requirements has been assured by compliance with:

EN IEC 60079-0:2018 EN 60079-1: 2014 EN 60079-31: 2014

except in respect of those requirements listed at item 18 of the Schedule.

- 10 If the sign "X" is placed after the certificate number, it indicates that the product is subject to the Specific Conditions of Use specified in the schedule to this certificate.
- This UK-TYPE EXAMINATION CERTIFICATE relates only to the design and construction of the specified 11 product. Further requirements of the Regulations apply to the manufacturing process and supply of this product. These are not covered by this certificate.
- 12 The marking of the product shall include the following :

 $\langle \overline{c_x} \rangle$ II 2GD Ex db IIC T6 Gb (-60°C \leq Ta \leq +65°C) / T5 Gb (-60°C \leq Ta \leq +80°C)

Ex tb IIIC T85°C Db (-60°C \leq Ta \leq +65°C) / T100°C Db (-60°C \leq Ta \leq +80°C)

SGS Baseefa Customer Reference No. 0279

Project File No. 22/0706

This document is issued by the Company subject to its General Conditions for Certification Services accessible at http://www.sgs.com/en/Terms-and-Conditions.aspx and the Supplementary Terms and Conditions accessible at http://www.sgs.com/SGSBaseefa/Terms-and-Conditions.aspx. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained herein reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. It does not necessarily indicate that the equipment may be used in particular industries or circumstances. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, schedule included, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.





R S SINCLAIR TECHNICAL MANAGER On behalf of SGS Baseefa Limited



Schedule

13 14

Certificate Number BAS22UKEX0060X – Issue 1

15 Description of Product

The Sentry Series Pressure & Temperature switches comprises a circular enclosure with a threaded cover, both manufactured in aluminium, stainless steel or cast iron. The enclosure base includes bosses for up to two threaded cable entries, and an extension housing the pressure/temperature operating mechanism.

The enclosure houses a 6 way terminal strip and up to two switch units, activated by a push rod passing through the enclosure wall.

The external operating mechanism is separated from the electrical enclosure by a vented chamber containing the push-rod, spring and adjusters. The unit may be fitted with a range of process connections for different pressure (or temperature) operations.

Internal and external earthing facilities are provided.

The cable entries are threaded M20 or M25 (or NPT equivalents) for the accommodation of flameproof cable entry devices, with or without the interposition of a flameproof thread adapter. Unused entries are to be fitted with certified flameproof stopping plugs.

The cable entry devices, thread adapters and stopping plugs shall be suitable for the equipment, the cable and the conditions of use and shall be certified as Ex Equipment and not as an Ex Component.

When used in an explosive dust atmosphere the cable entry devices shall maintain the ingress protection of the enclosure.

16 Report Number

See Certificate History

17 Specific Conditions of Use

- 1. The Flamepaths are not to be repaired
- 2. Warning Potential Electrostatic Charging Hazard See Instructions

18 Essential Health and Safety Requirements

In addition to the Essential Health and Safety Requirements (EHSRs) covered by the standards listed at item 9, the following are considered relevant to this product:

Clause	Subject
21(1)	External effects
21(2)	Aggressive substances, etc.

19 Drawings and Documents

New drawings submitted for this issue of certificate:

Number	Sheet	Issue	Issue Date	Release Date	Description
15681	1 of 1	D	29/03/2023	31/03/2023	Sentry Flameproof Nameplate
IECEx BAS 12.0081X					
Baseefa12ATEX0121X					



Current drawings which remain unaffected by this issue:

Number	Sheet	Issue	Issue Date	Release Date	Description
15678	1 of 1	В	06/09/2021	13/05/2022	Sentry Assembly Guide Drawing
15676	1 of 1	В	07/09/2021	13/05/2022	Sentry Flameproof Assembly SPDT
71079-SE- 003	1 of 1	А	08/09/2021	15/05/2022	Ex d Sentry Warning Marking
71097-SE- 004	1 of 1	А	07/09/2021	13/05/2022	Sentry Flameproof Assembly DPDT
71097-SE- 001	1 to 17	А	22/04/2022	-	Technical Specification for Flame Proof "Sentry" Series Switches
71098-ZZ- 001	1 to 5	А	22/04/2022	-	Technical Specification for sealing, grease and bonding materials used on switches

The drawings are common to IECEx BAS 12.0081X and Baseefa12ATEX0121X.

20 Certificate History

Certificate No.	Date	Comments
BAS22UKEX0060X	13 June 2022	The release of the prime certificate. The associated test and assessment against the requirements of EN IEC 60079-0:2018, EN 60079-1:2014 & EN60079-31:2014 and is documented in Test Report No. GB/BAS/ExTR22.0075/00
BAS22UKEX0060X Issue 1	6 April 2023	This new issue was raised in order to record a change of address of the manufacturer. A technical review of the certificate was not undertaken and a report was not prepared.
For drawings applicable to eac	h issue, see original	of that issue.