Delta Mobrey Limited Hudson House Albany Park Camberley Surrey, GU16 7PL United Kingdom

Declares under our sole responsibility as the manufacturer that the product:

Mobrey TM 4000 Pressure Transmitter

that this declaration relates to, conforms to the requirements of the applicable Directives of the European Union, including the latest amendments, as detailed in the attached schedule.

Presumption of conformity is based on the use of the harmonised standards and other technical documentation, and when applicable or required certification issued by a European Union notified body, as detailed in the attached schedule.

Signed

Name: Dr. Kapila Mediliyegedara

Designation: Certification Manager

Date: 30/06/2023

Place of Issue: Camberley, Surrey



Schedule

Description: Electronic Pressure Transmitter for use in process control applications.

Directive: Low Voltage (LVD) - 2014/35/EU

Safety Classification: "44" or "48"

Conformity Assessment: Module A

Standards: EN 61010-1:2010/A1:2019/AC:2019

Directive: Electromagnetic Compatibility (EMC) - 2014/30/EU

Conformity Assessment: Module A

Standards: EN 61326-1:2013 ; EN 61326-2-3:2013

Directive: ATEX - 2014/34/EU

Safety Classification: "22"

For intrinsically safe versions:

Provisions of the Directive fulfilled by the Equipment:



II 1G Ex ia IIC T4 (-25°C \leq Ta \leq +60°C)

EU Type Examination Certificate:

Sira 04ATEX2375X

Standards: EN 50014:1997 + Amds 1 & 2, EN 50020:2002, EN 50284:1999

(A review against EN IEC 60079-0:2018 and EN 60079-11:2012, which are harmonized,

shows this equipment is still considered to represent "State of the Art")



4000 Series

EU Declaration of **Conformity**



Schedule

Notified Body for EU-Type Examination:

Sira Certification Service, Hawarden, CH5 3US, UK, Notified Body No: 0518 CSA Group Netherlands B.V., Notified Body No: 2813

Notified Body for production:

SGS Fimko Oy, Helsinki, Finland. Notified Body No 0598

