

EU Declaration of **Conformity**



Delta Mobrey Limited
Hudson House
Albany Park
Camberley
Surrey, GU16 7PL
United Kingdom

Declares under our sole responsibility as the manufacturer that the product:

Volume Series
Pressure Switch
VM2, VM4

that this declaration relates to, conforms to the requirements of the applicable Directives of the European Union, including the latest amendments, as detailed in the attached schedule.

Presumption of conformity is based on the use of the harmonised standards and other technical documentation, and when applicable or required certification issued by a European Union notified body, as detailed in the attached schedule.

Signed

Kapilam

Name: Dr. Kapila Mediliyegedara
Designation: Certification Manager
Date: 24 March 2026
Place of Issue: Camberley, Surrey



EU Declaration of Conformity



Description: Pressure Switch for use in process control applications.

Directive: Low Voltage (LVD) - 2014/35/EU
Models: VM2, VM4.
Enclosure code: "A" (refer to table 1 of technical datasheet).
Conformity Assessment: Module A.
Standards: EN 60947-1:2007+A1:2011+A2:2014, EN 60947-5-1:2017+AC:2020,
 Self-certified by Delta Mobrey Ltd in accordance with Directive 2014/35/EU.

Directive: ATEX - 2014/34/EU
Models: VM2, VM4.
Enclosure code: "R" (refer to table 1 of technical datasheet).

For flameproof versions:

Provisions of the Directive fulfilled by the Equipment:



II 2G Ex db IIC T6 Gb (** ≤ Ta ≤ +65°C)
 Ex db IIC T5 Gb (** ≤ Ta ≤ +80°C)
 II 2D Ex tb IIIC T75°C Db (** ≤ Ta ≤ +65°C)
 Ex tb IIIC T90°C Db (** ≤ Ta ≤ +80°C)

** Fluorosilicone O-ring = -55°C; Nitrile O-ring = -35°C; Fluoroelastomer = -20°C

EU Type Examination Certificate:

ITS03ATEX11510X.

Standards: EN IEC 60079-0:2018, EN 60079-1:2014, EN 60079-31:2014.

Notified Body for EU-Type Examination:

INTERTEK Italia S.p.A., 20063 Cernusco sul Naviglio - Milano, Italy. Notified Body No 2575.

Notified Body for production:

SGS Fimko Oy, Helsinki, Finland. Notified Body No 0598.

Directive: Pressure Equipment (PED) - 2014/68/EU
Models: VM4.
Pressure: Static Pressure >200 Bar.
Conformity Assessment: Module A.
Standards: BS6134:1991.
 Self-certified by Delta Mobrey Ltd in accordance with Directive 2014/68/EU.

Models: VM2.
Pressure: Static Pressure ≤200 Bar.
Conformity Assessment: These transmitters with are manufactured on the basis of article 4.3 of directive 2014/68/EU in accordance with Sound Engineering Practice. In this case PED does not require CE marking, however products are CE marked due to requirements of other regulations of EU harmonised legislation.