

# EU Declaration of **Conformity**



**Delta Mobrey Limited  
Hudson House  
Albany Park  
Camberley  
Surrey, GU16 7PL  
United Kingdom**

Declares under our sole responsibility as the manufacturer that the product:

## **Performance Series**

that this declaration relates to, conforms to the requirements of the applicable Directives of the European Union, including the latest amendments, as detailed in the attached schedule.

Presumption of conformity is based on the use of the harmonised standards and other technical documentation, and when applicable or required certification issued by a European Union notified body, as detailed in the attached schedule.

### **Signed**

A handwritten signature in black ink, appearing to read "Dr. Kapila Mediliyegedara".

**Name:** Dr. Kapila Mediliyegedara  
**Designation:** Certification Manager  
**Date:** 21/11/2023  
**Place of Issue:** Camberley, Surrey

The CE mark, consisting of the letters "C" and "E" in a bold, sans-serif font, positioned to the left of a vertical blue bar.

Performance Series

# EU Declaration of Conformity



## Schedule

**Description:** Pressure, Differential Pressure, Temperature and Flow Switches for use in process control applications.

**Directive:** Low Voltage (LVD) - 2014/35/EU

**Models:** 200, 300, 700 & 131

**Enclosure code:** "W" or "A" (refer to table 1 of technical datasheet)

**Conformity Assessment:** Module A

**Standards:** EN 60947-1:2007+A1:2011+A2:2014, EN 60947-5-1:2017+AC:2020

**Directive:** ATEX - 2014/34/EU

For intrinsically safe versions:

**Models:** 200, 300, 700 & 131

**Enclosure code:** "H" or "K" (refer to table 1 of technical datasheet)

**Provisions of the Directive fulfilled by the Equipment:**



II 2G Ex db IIC T4 (-60°C ≤ Ta ≤ +80°C) Gb

Ex db IIC T6 (-60°C ≤ Ta ≤ +40°C) Gb

II 2D Ex tb IIIC T135°C (-60°C ≤ Ta ≤ +80°C) Db IP66

Ex tb IIIC T85°C (-60°C ≤ Ta ≤ +40°C) Db IP66

**EU Type Examination Certificate:**

BAS01ATEX2426X

**Standards:**

EN 60079-0:2012 +A11:2013, EN 60079-1:2014, EN 60079-31:2014

(a review against EN IEC 60079-0:2018 which is harmonized, shows this equipment is still considered to represent "State of the Art")

**Notified Body for EU-Type Examination:**

SGS Baseefa Ltd, Buxton, SK17 9RZ, UK, Notified Body No: 1180

SGS Fimko Oy, Helsinki, Finland. Notified Body No 0598

**Notified Body for production:**

SGS Fimko Oy, Helsinki, Finland. Notified Body No 0598



Performance Series