

## Statement of Compliance

No: 208 Rev B

### Delta Mobrey Ltd.

Hudson House, Albany Park, Camberley, Surrey,  
GU16 7PL, United Kingdom

Declares under our sole responsibility that the product(s):

Equipment: **D-Series: - Pressure, Differential Pressure, Level and Temperature Transmitters**

Type Numbers: \*D21\*\*\*\*\*, \*D22\*\*\*\*\*, \*D23\*\*\*\*\*, \*D31\*\*\*\*\*,  
\*D32\*\*\*\*\*, \*D33\*\*\*\*\*, \*D34\*\*\*\*\*, \*D35\*\*\*\*\*,  
\*D45\*\*\*\*\*, \*D72\*\*\*\*\*


(Minor variations in design to suit the application and/or mounting requirements are identified by alpha/numeric characters where indicated \* above)

### Ingress Protection Declaration

The products detailed above comply with the requirements of VDE 0470-1 / EN 60529 / IEC 60529 “Degrees of protection provided by enclosures (IP Code)” for degree of protection indicated below:

Enclosure	Model	Range	IP
All	*D21*****, *D31*****, *D34*****, *D35*****, *D45*****, *D72*****	All	66
All	*D21*****6*, *D31*****6*, *D34*****6*, *D35*****6*, *D45*****6*, *D72*****6*	All	67
B, D, C, F	*D23*****, *D32*****, *D33*****	All	65
G, K, J, L	*D23*****, *D32*****, *D33*****	All	66
M, N	*D23*****, *D32*****, *D33*****	All	67
O, P	*D32*****	All	66/67
Q, S, Z	*D23*****, *D32*****, *D33*****	All	68

Authorised Signatory for the manufacturer:



Signed:

Date: 12<sup>th</sup> December 2024

Dr. Kapila Mediliyegedara  
Certification Manager

**Your Trusted Partner in Process Instrumentation**

**Delta Mobrey Limited** Hudson House, Albany Park, Camberley, Surrey, GU16 7PL

T +44 (0) 1252 729140 F +44 (0) 1252 729168 E sales@delta-mobrey.com W www.delta-mobrey.com

Delta Mobrey Limited. Registered in England and Wales. Company No: 5389883. Registered office: Hudson House, Albany Park, Camberley, Surrey, GU16 7PL.