

Statement of Compliance

No: 200 Rev C

Delta Mobrey Ltd.

Hudson House, Albany Park, Camberley, Surrey,
GU16 7PL, United Kingdom

Declares under our sole responsibility that the product(s):

Equipment: **Performance Series
Pressure, Differential Pressure and Temperature switches**

Type Numbers: ***2*****, *3***** , *7*******

(Minor variations in design to suit the application and/or mounting requirements are identified by alpha/numeric characters where indicated * above)

Ingress Protection Declaration

The products detailed above comply with the requirements of VDE 0470-1 / EN 60529 / IEC 60529 "Degrees of protection provided by enclosures (IP Code)" for degree of protection indicated below:

Enclosure	Model	Range	IP
A, W, N, O	201/202/203/281	All except BC, C6, E1, E8, BU, CP, E4, E7	66
A, W, N, O	201/202/203/281	BC, C6, E1, E8, BU, CP, E4, E7	54
H, K	201/202/203/281	All	66
All	All except 201/2/3/281	All	66

Authorised Signatory for the manufacturer:

Signed: 

Date: 5th March 2025

Kapila Mediliyegedara
Certification Manager

Your Trusted Partner in Process Instrumentation

Delta Mobrey Limited Hudson House, Albany Park, Camberley, Surrey, GU16 7PL

T +44 (0) 1252 729140 F +44 (0) 1252 729168 E sales@delta-mobrey.com W www.delta-mobrey.com

Delta Mobrey Limited. Registered in England and Wales. Company No: 5389883. Registered office: Hudson House, Albany Park, Camberley, Surrey, GU16 7PL.