

EU Declaration of **Conformity**



**Delta Mobrey Limited
Hudson House
Albany Park
Camberley
Surrey, GU16 7PL
United Kingdom**

Declares under our sole responsibility as the manufacturer that the product:

Performance Series Switches Pressure, Differential Pressure, Temperature, Flow

that this declaration relates to, conforms to the requirements of the applicable Directives of the European Union, including the latest amendments, as detailed in the attached schedule.

Presumption of conformity is based on the use of the harmonised standards and other technical documentation, and when applicable or required certification issued by a European Union notified body, as detailed in the attached schedule.

Signed

A handwritten signature in black ink, appearing to be "Dr. Kapila Mediliyegedara".

Name: Dr. Kapila Mediliyegedara
Designation: Certification Manager
Date: 20/05/2025
Place of Issue: Camberley, Surrey



**Performance Series
Model: 200, 300, 700, 131**

EU Declaration of Conformity



Schedule

Description: Pressure, Differential Pressure, Temperature and Flow Switches for use in process control applications.

Directive: Low Voltage (LVD) - 2014/35/EU

Models: 2**, 3**, 7**, 131.

Enclosure code: "W" or "A" (refer to table 1 of technical datasheet)

Conformity Assessment: Module A

Standards: EN 60947-1:2007+A1:2011+A2:2014, EN 60947-5-1:2017+AC:2020,

Directive: ATEX - 2014/34/EU

Models: 20*, 23*, 28*, 30*, 38*, 7**, 131.

Enclosure code: "H" or "K" (refer to table 1 of technical datasheet)

For flameproof versions

Conformity Assessment: Module B + D

Provisions of the Directive fulfilled by the Equipment:



II 2G Ex db IIC T6 Gb (-60°C ≤ Ta ≤ +40°C)

Ex db IIC T4 Gb (-60°C ≤ Ta ≤ +80°C)

II 2D Ex tb IIIC T85°C Db (-60°C ≤ Ta ≤ +40°C)

Ex tb IIIC T135°C Db (-60°C ≤ Ta ≤ +80°C)

EU Type Examination Certificate:

BAS01ATEX2426X

Standards: EN IEC 60079-0:2018, EN 60079-1:2014, EN 60079-31:2014

Notified Body for EU-Type Examination:

SGS Fimko Oy, Helsinki, Finland. Notified Body No 0598

Notified Body for production:

SGS Fimko Oy, Helsinki, Finland. Notified Body No 0598



Performance Series
Model: 200, 300, 700, 131

EU Declaration of Conformity



Schedule

Models: 201, 203, 204, 207, 208, 209, 231, 301, 304, 306, 721, 731, 771.

Enclosure code: "O" (refer to table 1 of technical datasheet)

Switch Code: "H2", "H3", "H6" or "H9" (refer to table 6 of technical datasheet).

For increased safety versions

Conformity Assessment: Module A

Provisions of the Directive fulfilled by the Equipment:



II 3 GD Ex ec nC IIC T6 Gc ($-25^{\circ}\text{C} \leq \text{Ta} \leq +40^{\circ}\text{C}$)

Ex tc IIIC T85°C Dc ($-25^{\circ}\text{C} \leq \text{Ta} \leq +40^{\circ}\text{C}$)

Ex ec nC IIC T4 Gc ($-25^{\circ}\text{C} \leq \text{Ta} \leq +80^{\circ}\text{C}$)

Ex tc IIIC T135°C Dc ($-25^{\circ}\text{C} \leq \text{Ta} \leq +80^{\circ}\text{C}$)

Standards: EN IEC 60079-0:2018, EN 60079-7:2015+A1:2018, EN IEC 60079-15:2019, EN 60079-31:2014

Self certified by Delta Mobrey Ltd based on ExVeritas 23ATEX1609X.

Directive: Pressure Equipment (PED) - 2014/68/EU

Models: 2**, 3**.

Pressure: Static Pressure >200 Bar.

Conformity Assessment: Module A

Standards: BS 6134:1991 Pressure and Vacuum Switches

Directive: Restriction of Hazardous Substances (RoHS) - 2011/65/EU

Models: 2**, 3**, 7**, 131.

Conformity Assessment: Module A

Standards: EN IEC 63000:2018



Performance Series
Model: 200, 300, 700, 131