EU Declaration of **Conformity**



Delta Mobrey Limited Hudson House Albany Park Camberley Surrey, GU16 7PL United Kingdom

Declares under our sole responsibility as the manufacturer that the product:

Industrial Series Switches Pressure, Differential Pressure, Temperature

that this declaration relates to, conforms to the requirements of the applicable Directives of the European Union, including the latest amendments, as detailed in the attached schedule.

Presumption of conformity is based on the use of the harmonised standards and other technical documentation, and when applicable or required certification issued by a European Union notified body, as detailed in the attached schedule.

Signed

مريكي

Name: Dr. Kapila Mediliyegedara Designation: Certification Manager

Date: 21/10/2025

Place of Issue: Camberley, Surrey



Schedule

Description: Pressure, Differential Pressure, and Temperature Switches for use in process

control applications.

Directive: Low Voltage (LVD) - 2014/35/EU

Models: *S21*, *S22*, *S24*, *S31*, *S34*, *S71*.

Enclosure code: "W" or "A" (refer to table 1 of technical datasheet).

Conformity Assessment: Module A.

Standards: EN 60947-1:2007+A1:2011+A2:2014, EN 60947-5-1:2017+AC:2020.

Self certified by Delta Mobrey Ltd in accordance with Directive 2014/35/EU.

Directive: ATEX - 2014/34/EU

For intrinsically safe versions:

Models: *S21*, *S22*, *S24*, *S31*, *S34*, *S71*.

Enclosure code: "4" or "5" (refer to table 1 of technical datasheet).

Provisions of the Directive fulfilled by the Equipment:

 $\langle E_{x} \rangle$

II 1G Ex ia IIC T6 Ga (-25° C \leq Ta \leq +60 $^{\circ}$ C)

II 1G Ex ia IIC T5 Ga (-60° C \leq Ta \leq +80 $^{\circ}$ C)

EU Type Examination Certificate:

Baseefa05ATEX0111

Standards:

EN 60079-0:2018, EN 60079-11:2012.

Notified Body for EU-Type Examination:

SGS Fimko Oy, Helsinki, Finland. Notified Body No 0598

Notified Body for production:

SGS Fimko Oy, Helsinki, Finland. Notified Body No 0598

For flameproof versions

Models: *S21*, *S22*, *S24*, *S31*, *S34*, *S71*.

Enclosure code: "H" or "R" (refer to table 1 of technical datasheet).

Provisions of the Directive fulfilled by the Equipment:



II 2G Ex db IIC T6 Gb (** \leq Ta \leq +65°C)

Ex db IIC T5 Gb (** \leq Ta \leq +80°C)

II 2D Ex tb IIIC T85°C Db (** \leq Ta \leq +65°C)

Ex tb IIIC T100°C Db (** \leq Ta \leq +80°C)

** Fluorosilicone O-ring = -60°C; Nitrile O-ring = -30°C

Standards: EN 60079-0:2018, EN 60079-1:2014, EN 60079-31:2014.



ndustrial Series Models: S2*, S3*,

Schedule

For flameproof versions

Models: S24.

Enclosure code: "2" or "3" (refer to table 1 of technical datasheet).

Provisions of the Directive fulfilled by the Equipment:

II 1/2 G Ex db IIC T6 Ga/Gb (** \leq Ta \leq +65°C)

Ex db IIC T5 Ga/Gb (** ≤ Ta ≤ +80°C)

II 1/2 D Ex ta/tb IIIC T85°C Da/Db (** \leq Ta \leq +65°C)

Ex ta/tb IIIC T100°C Da/Db (** \leq Ta \leq +80°C)

** Fluorosilicone O-ring = -60°C; Nitrile O-ring = -30°C

Standards: EN IEC 60079-0:2018, EN 60079-1:2014, EN 60079-31:2014,

EN 60079-26:2015.

EU Type Examination Certificate:

BAS01ATEX2113X

Notified Body for EU-Type Examination:

SGS Fimko Oy, Helsinki, Finland. Notified Body No 0598

Notified Body for production:

SGS Fimko Oy, Helsinki, Finland. Notified Body No 0598

Directive: Pressure Equipment (PED) - 2014/68/EU

Models: *S24*, *S34*

Conformity Assessment: Module A

Standards: BS 6134:1991 Pressure and Vacuum Switches

Self certified by Delta Mobrey Ltd in accordance with Directive 2014/68/EU.

Models: *S21*, *S22*, *S31*
Pressure: Static Pressure ≤200 Bar.

Conformity Assessment: These transmitters with are manufactured on the basis of article 4.3 of

directive 2014/68/EU in accordance with Sound Engineering Practice. In this case PED does not require CE marking, however products are CE marked due

to requirements of other regulations of EU harmonised legislation.

(